



City of Hazel Park
Landlord Licensing Program
111 E Nine Mile Road
Hazel Park, MI 48030
(248)546-4075

FURNACE/HEATING PLANT INSPECTION RECORD
(INSPECTION MUST BE MADE WITHIN 7 DAYS OF INITIAL INSPECTION)

Property
Address: _____

Date Work Performed: _____

Contractor Name: _____

Contractor Address: _____

Phone: _____ Fax: _____

Contractor's State License Number: _____

Technician's Name: _____

Technician's State License Number (if applicable): _____

I hereby certify that I have operated and inspected all the gas and/or oil-fired heating equipment at the above referenced address as follows:

1. Heat exchangers were visually inspected if accessible.
2. Carbon Monoxide tests were performed in the discharge air plenum and in the immediate vicinity of the unit(s). CO reading: In plenum _____ In vicinity _____.
3. All system controls and safety switches were inspected for proper operation.
4. 110 v electrical system was inspected. On/off switch checked for proper operation.
5. All filters were inspected.
6. No deficiencies were found. All tests and equipment were within normal operating limits.

Signature

Date